

Intertek ETL SEMKO

AUTHORIZATION TO MARK

HEATIZON
NOV 29 2004
RECEIVE

This authorizes the application of the Certification Mark(s) shown below to the models described in the Product(s) Covered section when made in accordance with the conditions set forth in the Certification Agreement and Listing Report. This authorization also applies to multiple listee model(s) identified on the correlation page of the Listing Report.

Applicant: Heatwave LLC dba Heatizon Systems
4403 South 500 West
Murray, UT 84123

Contact: Name: Mr. Russell Childs Phone: 801.293.1232 FAX: 801.293.307

Manufacturer: Same as Applicant

Party Authorized To Apply Mark: Same as Manufacturer

Report Issuing Office: Beaverton, Oregon 97006 USA

Report No.: J97018160-001

Product Covered: Radiant Heating and Snow Melting Systems Models Cable Heater E101 (Tuff-Cable) and Screen Heater E102 (Z-Mesh).

Description: The heating and snow melting systems are low voltage (<60 VAC). It is intended to be embedded in concrete, on concrete, within subfloors, and under any type of floor covering installed in accordance with the applicable articles 424 and 426 of the National Electric Code.

The systems consist of a solid state control board which monitors ambient temperature, heating element current, and transformer temperature. Protection is provided for overcurrent, undercurrent, high transformer temperature, arcing, and shorting of the thermistor. The system utilized 2 AWG THHN copper wire from the transformer to the heating element E101, which is 10 AWG THHN copper wire embedded in the concrete, , spread a minimum of 1-inch apart. For additional information and proper parts list, see installation manual in the illustration instruction of this report.

The systems described above is the same for the screen heating element (E102). The screen heating element is installed on the concrete, on wood subfloor, under any type of floor covering too. The screen element is bronze mesh 9 to 12 inches wide and can be spaced a minimum 2 inches apart.

Standard(s): Electric Radiant Heating Panels and Heating Panel Sets (UL 1693, 1st Ed. 05/18/95)

This document is the property of Intertek Testing Services and is not transferable. Only the Applicant may reproduce this document. The certification mark(s) may be applied only at the above noted location of the Party Authorized To Apply Mark.



Authorized by: William T. Starr Date: November 18, 2004
William T. Starr, Certification Manager

Control Number: 9700682

This document supercedes all previous Authorizations to Mark for the noted Report Number.
Intertek Testing Services NA Inc.
165 Main Street, Cortland, NY 13045
Telephone 800-345-3851 or 607-753-6711 Fax 607-756-6699